

25



City of West Allis

Matter Summary

7525 W. Greenfield Ave.
West Allis, WI 53214

File Number	Title	Status
2003-0236	Communication	In Committee
Communication from City Engineer regarding poor brick work on the new Fire Station No. 1		
Introduced: 4/15/2003		Controlling Body: Public Works Committee

COMMITTEE RECOMMENDATION ~~Approved~~ Place on file

MOVER: VITALE AYES 4 NOES 0

SECONDER: KOPPLIN EXCUSED SENGSTOCK

COMMITTEE ACTION DATE 4-15-03

SIGNATURES OF COMMITTEE MEMBERS

[Signature] Chair Vice-Chair

COMMON COUNCIL ACTION placed on file

FINAL ACTION DATE April 15, 2003

MOVER:
Narlock

SECONDER:
Vitale

	AYE	NO
1. Barczak	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Czaplewski	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Kopplin	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Lajszic	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Murphy	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6. Narlock	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Reinke	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8. Sengstock	<u>exc</u>	<input type="checkbox"/>
9. Trudell	<input checked="" type="checkbox"/>	<input type="checkbox"/>
10. Vitale	<input checked="" type="checkbox"/>	<input type="checkbox"/>
TOTAL	<u>9</u>	<input type="checkbox"/>



CITY OF WEST ALLIS

WISCONSIN



Engineering Department

MICHAEL G. LEWIS
City Engineer

April 10, 2003

Board of Public Works
City of West Allis
West Allis, WI 53214

RE: Poor Brick Work on New Fire Station No. 1

Dear Board Members:

I want to talk about the poor brickwork on the New Fire Station No. 1 on Tuesday night. We have scheduled a meeting with the General Contractor and mason subcontractor on Friday afternoon and the results of that meeting and our options will be discussed on Tuesday.

If you have a chance, stop by and take a look at the north and east sides. You will notice that the brick has a blotchy, freckled look. The brick should have been sorted by color before placement. The mortar is also off color which compounds the look of the off color brick work.

Respectfully,

Michael G. Lewis
City Engineer

MGL/mgl

Cc: Fire Chief Steven Hook
Michael Pertmer, Director of Public Works