



City of West Allis Matter Summary

7525 W. Greenfield Ave.
West Allis, WI 53214

File Number	Title	Status
2008-0455	Communication	In Committee
	Communication from City Engineer Regarding Extending Storm Sewer to 1001 South 97th Street	
	Introduced: 6/17/2008	Controlling Body: Public Works Committee

COMMITTEE RECOMMENDATION Approve

ACTION DATE:	MOVER	SECONDER		AYE	NO	PRESENT	EXCUSED
<u>6-17-08</u>			Barczak				
		✓	Czaplewski	✓			
			Kopplin				
			Lajsic				
			Narlock				
			Reinke				
			Roadt	✓			
	✓		Sengstock	✓			
			Vitale				
			Weigel				✓
			TOTAL	<u>4</u>			<u>1</u>

SIGNATURE OF COMMITTEE MEMBER

Henry R. Borell _____
 Chair Vice-Chair Member

COMMON COUNCIL ACTION **APPROVAL**

ACTION DATE:	MOVER	SECONDER		AYE	NO	PRESENT	EXCUSED
<u>JUN 17 2008</u>	✓		Barczak	✓			
			Czaplewski	✓			
			Kopplin	✓			
			Lajsic	✓			
		✓	Narlock	✓			
			Reinke	✓			
			Roadt	✓			
			Sengstock	✓			
			Vitale	✓			
			Weigel				✓
			TOTAL	<u>9</u>			<u>1</u>



ENGINEERING DEPARTMENT

Michael G. Lewis
City Engineer

414/302-8360
414/302-8366 (Fax)

City Hall
7525 West Greenfield Avenue
West Allis, Wisconsin 53214

www.ci.west-allis.wi.us
mlewis@ci.west-allis.wi.us

June 12, 2008

Board of Public Works
City of West Allis
West Allis, WI 53214

**RE: Communication from City Engineer Regarding Extending Storm Sewer to
1001 South 97th Street**


Dear Board Members:

Attached is a plan showing the intended storm sewer extension. The Building Department has ordered the owner to connect to storm sewer. We have inspected the property and agree that they have a water problem and it's affecting the sidewalk and street. Unfortunately, there is no other solution than to extend storm sewer to them. Their assessment cost would be \$807. The Board has authorized similar work in the past and it's consistent with current policy. We are asking for approval of the project and to add this work to a future contract. It would be done this year.

Respectfully,

Michael G. Lewis
City Engineer

MGL/mgl



1001 5.97 ST.
 OWNER IS CITY BY
 CITY FOR DRAINAGE
 ACROSS SIDEWALK.
 NO PLACE TO RUN STORM
 MAIN - \$807.00 STANDARD ASSESSMENT

SEWERAL YARDS
 DRAIN TO 1001

PROP. STORM →

97TH ST

CONSTRUCTION ESTIMATE:

- 175 LIN. FT. OF 8" STORM @ 85/FT = 14,875
- 5 LIN. FT. OF 6" STORM LAT @ 50/FT = 250
- 1 CLEAN-OUT = 500
- LAWN REPLACEMENT = 250
- SIDEWALK REPLACEMENT = 750

TOTAL COST EST. = \$16,625

