



Food Truck *Mr BBQ* Check List

Vendor Name: Jenval Williams
 Date Inspected: 12-7-17
 Inspected By: DE M. Dombrowski

Extinguishers	
<input checked="" type="checkbox"/>	2A10BC w/tag
<input checked="" type="checkbox"/>	K-Extinguisher w/tag
	Visible & Unobstructed

Fire Extinguishing Systems	
	Hood & Duct annual certification
	Current inspection/Service tag
	Cleaned (annually, semi-annually, quarterly)
	Frying surface of more than two square feet w/ no hood

Electrical/Extension Cords	
	Extension cords are not properly rated for use according to manufacturer's requirements/ungrounded cords
<input checked="" type="checkbox"/>	Extension cords are a substitute for permanent wiring
<input checked="" type="checkbox"/>	Extension cords are affixed to structures, extended through walls, ceilings, floors, under doors, and floor coverings
	"Piggybacking" of extension cords and/or power strips are present
	Halogen lights are present (hazardous to people and property)

Storage of Flammable Liquids & Combustibles	
<input checked="" type="checkbox"/>	Storage of gasoline present
<input checked="" type="checkbox"/>	Storage of liquid petroleum (LP) present
	Three (3) feet of clearance near all cooking equipment not met

Vehicle/Trailer Location	
	Blocking fire lane, hydrant, exit access of any structures

General Safety	
<input checked="" type="checkbox"/>	Engine-driven source of power is not separated from the public by a barrier-guards, fencing, or enclosures
	Refueling during hours of operation
	Accumulation of rubbish creating a nuisance or hazard to public health, safety, or welfare
	Cooking equipment left unattended while still hot or in use

Notes:
State lic was not current.
Returned on 12-12-17 All items corrected