

MEMORANDUM

TO: Michael G. Lewis, City Engineer/Director of Public Works
FROM: Joseph M. Burtch, Assistant City Engineer
DATE: July 22, 2015
RE: Repair of Sanitary Lateral Connection at 10025 W. Bungalow Parkway

The property owner of 10025 W. Bungalow Parkway experienced a back-up of their sanitary lateral. They hired a contractor to clear the line and found it to be in poor condition. The televised inspection showed a possible problem at the connection. Musson Bros., Inc. inspected the connection from the main sewer and it was determined that the connection was failing and a section of the pipe was missing. Musson Bros., Inc. provided a proposal to line the connection for a cost of \$3,250. I told them to go ahead with the lining, since digging the connection would cost \$5,000 to \$7,000 more. Musson Bros., Inc. completed the repair and provided a televised inspection of the lining.